



Aalborg Universitet

AALBORG UNIVERSITY
DENMARK

Machine Learning based Operating Region Extension of Modular Multilevel Converters under Unbalanced Grid Faults

Wang, Songda; Dragicevic, Tomislav; Gao, Yuan; Chaudhary, Sanjay K.; Teodorescu, Remus

Published in:
I E E E Transactions on Industrial Electronics

DOI (link to publication from Publisher):
[10.1109/TIE.2020.2982109](https://doi.org/10.1109/TIE.2020.2982109)

Publication date:
2021

Document Version
Accepted author manuscript, peer reviewed version

[Link to publication from Aalborg University](#)

Citation for published version (APA):
Wang, S., Dragicevic, T., Gao, Y., Chaudhary, S. K., & Teodorescu, R. (2021). Machine Learning based Operating Region Extension of Modular Multilevel Converters under Unbalanced Grid Faults. *I E E E Transactions on Industrial Electronics*, 68(5), 4554-4560. [9047163]. <https://doi.org/10.1109/TIE.2020.2982109>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

Machine Learning based Operating Region Extension of Modular Multilevel Converters under Unbalanced Grid Faults

Songda Wang, Tomislav Dragicevic, *Senior Member, IEEE*, Yuan Gao, *Student Member, IEEE*, Sanjay K Chaudhary, *Senior Member, IEEE*, and Remus Teodorescu, *Fellow, IEEE*

Abstract— The capacitor voltage ripples of the modular multilevel converter (MMC) are increased under unbalanced grid fault conditions. Since high capacitor voltage ripples deteriorate their lifetimes and may even cause tripping of the MMC system, it is important to restrict them. To this end, it is well known that injecting double fundamental frequency circulating currents can reduce the capacitor voltage ripples. However, finding a proper circulating current reference to achieve desired ripples analytically is complicated. This paper proposes an alternative method to quickly calculate the proper circulating current references without analytical computations, which is achieved by an artificial neural network (ANN) trained to approximate the relationship between circulating current references and capacitor voltage ripples. The training data is firstly extracted from a detailed simulation model of the MMC. Afterwards, the ANN is trained by the input-output data to obtain the mapping relationship, which is then used to derive the desired circulating current references. Both the simulation and the experimental results verify the practicability of the proposed method, where the operating region can be extended 30% at a minimum in all testing conditions.

Index Terms— Modular multilevel converter (MMC), artificial neural network (ANN), operating region extension, capacitor voltage ripple reduction, machine learning.

I. INTRODUCTION

THE modular multilevel converter (MMC) is one of the most attractive topologies for voltage source converter-based high voltage direct current (HVDC) systems due to MMC's advanced merits: modularity, scalability, lower harmonics, and small (or no) harmonic filter requirements [1].

Unbalanced grid conditions during asymmetric faults affect the charging of the MMC submodule (SM) capacitors. As a result, the capacitor voltage ripples will be unbalanced and will present higher amplitudes [2]. High SM capacitor voltages will

cause tripping of the MMC system immediately if they exceed the safe voltage limit [3]. Therefore, the safe operating region of the MMC is limited during such faults [4]. Moreover, the SM capacitors will deteriorate more quickly through the aging process if they are subjected to high voltage operation [5]. Aging gradually reduces their capacitance, and with aging the capacitor voltage will get even higher under unbalanced grid fault conditions.

Several approaches have been proposed to address operation region extension by reducing SM capacitor voltage ripples under different grid conditions. In [4], the operating region is extended by injecting the second-order harmonic circulating current under single phase grid fault condition. However, in this paper the amplitude of injected AC circulating current is fixed, which means that different three-phase unbalanced grid fault conditions have not been addressed. Therefore, this method cannot flexibly control the voltage according to different fault conditions. In [6], the second-order harmonic circulating current injection method is combined with the optimized zero-sequence voltage to extend the operation region. Still, the method in [6] is only designed for balanced grid condition. In [7], AC circulating current reference is derived from the instantaneous capacitance with the upper and lower arm under single-phase grid. Then the SM capacitor voltage ripple can be reduced. This instantaneous method is also applied under unbalanced grid condition in [8], and the results showed that this method can also reduce the SM capacitor voltage ripple under unbalanced grid conditions. However, these papers applied the method of injecting circulating currents regardless of whether SM voltages of these phases exceed the safe limit or not. If so, unnecessary power losses will occur in the phase that does not exceed the safe voltage limit. In [9]–[11], analytical equations are introduced to model submodule voltage ripple under balanced grid condition. However, these ripple equations do not consider the influence of unbalanced grid condition, since deriving the equations for the unbalance-grid-condition case would be very complicated and time-consuming because of the extra negative-sequence current/voltage. Their derivation also requires strong control and domain expertise, which makes them difficult to reproduce and understand by practicing engineers. In [12]–[14], the components of the circulating current under unbalanced grid conditions are analyzed and a circulating current control is proposed in order to suppress all the AC components of circulating current. However,

Manuscript received August 15 2019, first revised November 5 2019, second revised December 24 2019, third revised February 06 2020, accepted February 28 2020. (Corresponding Author: Yuan Gao).

S. Wang, T. Dragicevic, S. K. Chaudhary, and R. Teodorescu are with the Department of Energy Technology, Aalborg University, Aalborg, Denmark. (email: sow@et.aau.dk; tdr@et.aau.dk; skc@et.aau.dk; ret@et.aau.dk).

Y. Gao is with the Department of Electrical and Electronic Engineering, University of Nottingham, Nottingham, UK. (email: Yuan.Gao@nottingham.ac.uk).




Fig. 1. Training steps for the ANN method.




Fig. 2. The control block diagram of proposed MMC.

suppressing all the AC circulating currents will not guarantee that the voltage ripples in the submodule capacitors do not exceed the voltage limits. In [15], an analytical relationship between MMC arm power and circulating current references is derived. Then, the circulating current reference that reduces the submodule capacitor voltage ripple is calculated based on derived equations. However, [15] only analyzes the arm power of the MMC with different control techniques, whereas the accurate relation between submodule capacitor voltage ripples and circulating current references is not discussed. In other words, the theoretical foundation set in [15] is not sufficient to explicitly derive circulating current references for controlling three-phase SM submodule capacitor voltage ripples. In [3], an offset pulse-width modulation (OPWM) and zero sequence voltage injection method is proposed. The three-phase offsets added to the duty ratios to reduce the average SM capacitor voltages of the arms during unbalanced grid conditions [3]. However, this paper still does not address the accurate relation between submodule capacitor voltage ripples and circulating current references. In [16], a non-linear optimization method which can extend the operating region by on-line model predictive method is proposed. Moreover, this method is combined with frequency-domain models of MMC, which can eliminate the need for time-consuming simulations. However,

in this paper, the overall control structure is different from the widely-use traditional MMC control structure because of the non-linear H-infinity output current controller and predictive control regulator. This new control structure with non-linear controller requires high knowledge level for implementation, which may make the practical application quite challenging.

Discussion above underlies the need of developing simple and easily generalizable control methods for compensation of SM capacitor voltage ripples under unbalanced grid conditions. This paper proposes a flexible and computationally light ripple-compensation technique based on trained artificial neural network (ANN) that acts as a fast surrogate model mapping the relationship between circulating-current references and SM capacitor voltage ripples. With the help of this ANN model, the injected circulating current references are calculated automatically according to different grid conditions. In addition, desired capacitor-voltage-ripple values, which are limited to some predefined operating range, can be obtained explicitly. The ANN is trained by the data collected from simulations, and the application of the proposed method has been experimentally demonstrated.

II. ANN BASED APPROACH

A. Deployment of ANN

Several papers have used ANN to solve power electronics problems, from selecting weighting factors in model predictive control of power electronics converters [17] to automatically designing the power electronics system for reliability [18]. ANN is known to be a universal function approximator. In other words, it can in theory approximate any function with arbitrary precision, given that the number of layers and neurons has been appropriately chosen [19]. In practice, ANN structure is usually selected by trial-and-error.

The surrogate model in this paper is constructed by using a 3-layer ANN, where there are 9 neurons in the hidden layer. This surrogate model represents the relationship between circulating current, grid dip severity factor, and injected circulating current amplitude. In particular, this network represents the following relation:

$$y = F(x) \Leftrightarrow (\hat{I}_{cAcA}, \hat{I}_{cAcB}, \hat{I}_{cAcC}) = F(D, \hat{V}_{cua}, \hat{V}_{cub}, \hat{V}_{cuc}) \quad (1)$$

where \hat{I}_{cAcA} , \hat{I}_{cAcB} , \hat{I}_{cAcC} are circulating currents, \hat{V}_{cua} , \hat{V}_{cub} , \hat{V}_{cuc} are capacitor voltages, and D is grid dip severity factor. The severity of two-phase-to-ground grid fault depends on D . The range of D is [0,1], where 1 means normal grid, and 0 means short circuit, more practices about D can be found in [20] and [21].

B. Design and Collection of Sample Data for ANN

ANN feedback is triggered when the unbalanced grid detector detects an unbalanced grid fault. After training, the ANN can give feasible circulating current references (\hat{I}_{cAc}) to control the SM capacitor voltages in a desired way. This paper takes two-phase-to-ground grid fault as an example. The vector definition of the two-phase-to-ground grid fault can be described based on [20] as:

$$\hat{V}_{ga_pu} = 1, \hat{V}_{gb_pu} = -\frac{1}{2}D - j\frac{\sqrt{3}}{2}D, \hat{V}_{gc_pu} = -\frac{1}{2}D + j\frac{\sqrt{3}}{2}D \quad (2)$$

where $\hat{V}_{ga_pu}, \hat{V}_{gb_pu}, \hat{V}_{gc_pu}$ are per unit values of the grid voltages in phase a, b, and c.

Circulating current circulates inside the MMC without affecting the AC output currents. It only influences the internal performance of the MMC system. In this paper, we define the circulating current as a parameter containing both DC and AC components:

$$i_{ck} = \frac{i_{uk} + i_{lk}}{2} = I_{ckDC} + \hat{I}_{cACk} \cos(2\omega t + \theta_{vk-}) \quad (3)$$

where k is phase number of three-phase system (0 for phase A, 1 for phase B, and 2 for phase C), i_{ck} is three-phase circulating currents, i_{uk} and i_{lk} are the upper and lower arm current respectively. I_{ckDC} is the DC component of circulating current, $\hat{I}_{cACk} \cos(2\omega t + \theta_{vk-})$ is AC component of three-phase circulating current, ω is fundamental angular frequency, and θ_{vk-} is the phase angle of negative-sequence voltage. The injected AC circulating currents are double fundamental frequency, negative-sequence phases $[0, -4/3\pi, -2/3\pi]$ with different amplitudes ($\hat{I}_{cACa}, \hat{I}_{cACb}, \hat{I}_{cACc}$). In this paper, we only consider AC circulating current components.

To clarify the training procedures, all the steps are shown in Fig. 1. Each step is further elaborated as follows.

1) Generation of N data samples from simulation to extract $\hat{V}_{cua}, \hat{V}_{cub}, \hat{V}_{cuc}$ for every combination of $\hat{I}_{cACa}, \hat{I}_{cACb}, \hat{I}_{cACc}$ and D .

The data can be extracted either from a detailed simulation or from an experimental setup. In this work, we collected data from simulations and verified the method both in a high voltage simulation model and in a low voltage experimental setup. In the simulation, the sweep values of input data are: grid dip severity $D = [0.5, 0.6, 0.7, 0.8, 0.9]$; three circulating currents $\hat{I}_{cACa,b,c} = [0, 50, 100, 150, 250, 300, 350, 400]$ for three phases a, b, c ; the output data are three capacitor voltages $\hat{V}_{cua,b,c}$. The total number of data points is hence $5 \times 8 \times 8 \times 8 = 2560$. The paralleled simulations helped us to accelerate the simulation process. In particular, a workstation with a 24-core CPU was utilized for the data collection. Since the execution time was around 8 sec for one simulation, the overall simulation time for 2560 samples was approximately 14 mins. In the model that resembles the experimental setup, the sweep values of input data were: $D = [0.5, 0.6, 0.7, 0.8, 0.9]$, $\hat{I}_{cACa,b,c} = [0.3, 0.5, 0.7, 0.9, 1.1, 1.3, 1.5]$. The output data was the same $\hat{V}_{cua,b,c}$. The number of data points was 1715, and the overall data collection time for 1715 data was approximately 10 mins.

2) Reduction of the capacitor voltage amplitudes using ANN

The extracted data was used to train the desired surrogate model, which represents the relationship between \hat{V}_{cu} , D , and \hat{I}_{cAC} under two-phase-to-ground faults conditions.

The trained ANN model was finally used to calculate the

injected circulating current references for the MMC system under two-phase-to-ground grid faults. The inputs of the ANN model are the grid dip severity factor D and safe SM capacitor voltage limit, then the outputs of the ANN are the three-phase circulating current references. The trained ANN model was compiled to SIMULINK model. This model can both be applied in the PLECS Blockset software (for offline simulation) and in the dSPACE DS1006 platform (for real-time control).

III. RESULTS

The control block diagram of the proposed method is shown in Fig. 2. The MMC controller is divided into two main parts. 1). Proposed ANN and Circulating Current Controller: When two-phase-to-ground fault happens, the proposed ANN model will generate three-phase circulating current references based on desired capacitor voltages and detected D . Then, the circulating current controller enables the MMC to track its circulating current references. In this paper, the proportional resonant (PR) controller is used to track the AC circulating current [11]. The proposed ripple reduction method reduces the SM voltage ripple by injecting AC circulating current under unbalanced grid conditions. Energy controller ensures that the total amount of energy stored inside the converter is always controllable to stabilize the MMC system under unbalanced grid conditions. By energy controller, two types of energies are controlled. We refer to them as the ‘‘Sum’’ energy and the ‘‘Delta’’ energy. Sum energy is the sum of upper arm energy and lower arm energy; Delta energy is the difference between upper arm energy and lower arm energy. The detailed information about these two energy controllers can be found in [11] and [22]. The three-phase sum energies are controlled to a same level and the delta energies are controlled to zero. 2). Output Current Controller: PR controller is used in the output controller to control the output current of the MMC in grid-connected operation. This controller is conventional, and more details can be found in [11].

A. Simulation Results

The proposed ANN SM capacitor voltage ripple reduction method was first validated by PLECS simulation. The specifications of the simulation model are listed in Table I. The simulation results of MMC under balanced grid conditions are shown in Fig. 3. Fig. 3 (a1) shows the three-phase SM capacitor voltages under balanced grid condition. These voltages are balanced and within the safe voltage limit of around 10% of the nominal value. The average voltage ripple (peak to peak value of capacitor voltage) here is 38.72 kV. The unbalanced degree is 0.046%, unbalanced degree (UD) is defined in (4) as

$$UD = [\max(V_a, V_b, V_c) - \min(V_a, V_b, V_c)] / V_{avg} + (V_a + V_b + V_c) / 3 \quad (4)$$

Fig. 3 (b1) - (b3) show the SM capacitor voltages under two-phase-to-ground grid faults. The capacitor voltages are unbalanced and exceed the safe voltage limit. The average ripple increases to 46.03 kV, and the UD increases to 1.48%.




Fig. 3. Simulation results: (a) normal grid condition; (b) unbalanced grid condition without proposed method; (c) unbalanced grid condition with proposed method.

The results of the proposed method are presented in Fig. 3 (c1) - (c3). The circulating current components are injected into the MMC system. Injected AC circulating currents are calculated by the ANN model, the amplitudes of them are $\hat{I}_{ACa} = 60.53$ A, $\hat{I}_{ACb} = 551$ A, $\hat{I}_{ACc} = 480.8$ A respectively. It can




Fig. 5. Injected circulating current components

TABLE I
MMC PARAMETERS IN SIMULATION AND EXPERIMENT

	Simulation	Experiment
Number of SMs per arm (N)	100	4
Rated DC voltage (v_d)	200 kV	200 V
Rated active power	150 MW	1 kW
Nominal SM capacitance (C)	3.75 mF	2000 μ F
Nominal SM capacitor voltage (v_c)	2 kV	50 V
Rated frequency (f)	50 Hz	50 Hz
Arm inductance (L)	50.9 mH	10 mH
Sample frequency	10 kHz	10 kHz
Grid voltage magnitude	100 kV	83 V
Dip severity grid factor in two-phase-to-ground fault (D)	0.7	0.5




Fig. 4. Grid connected MMC diagram.

be noticed that the three-phase injected circulating currents are not symmetrical. In this way, the losses of the MMC are lower because the root mean square current in phase a is low. The capacitor voltages of the proposed method are within the safe limit, as shown in Fig. 3 (c1). The average ripple is reduced to 39.87 kV, and this voltage is reduced to the same level of capacitor voltage under balanced grid conditions. The UD here is reduced to 0.64%. In this case, the operating region is extended 30% because the proposed ANN method prevents MMC capacitor overvoltage trip when $D=0.7$.

In this paper, the injected AC circulating current components are flexible, which means the amplitudes of injected AC circulating current can be varied. Therefore, the three-phase components with different amplitudes usually contain positive-, negative- and zero-sequence components. The injected circulating current components are shown in Fig. 5.

B. Experimental Results

The proposed ANN capacitor voltage reduction method is also demonstrated in an experimental setup. The experiment is carried out in a scaled-down three-phase grid-connected MMC setup with 4 half-bridge SMs per arm. The MMC controller is implemented in DS1006 from dSPACE. The specifications of the experimental setup are also listed in Table I. The data points for experiments were collected from a detailed simulation model using the same parameters with the lab setup. In this way, the data extraction time was greatly saved.

Similar to the simulation results, three-phase capacitor voltages are balanced under balanced grid. In addition, the voltage is within the safe limit, as shown in Fig. 6 (a1). The average ripple is 6.5 V, and the UD is 0.18%.

The capacitor voltages become unbalanced under two-phase-to-ground faults. Moreover, the capacitor voltage amplitudes exceed the limit, which is shown in Fig. 6 (b1). The average ripple increases to 7.3 V. The UD increases to 1.112%.




Fig. 6. Experimental results: (a) normal grid condition; (b) unbalanced grid condition without proposed method; (c) unbalanced grid condition with proposed method.

The proposed method can also reduce the capacitor voltages to a safe voltage limit in the experiment as shown in Fig. 6 (c1). The amplitudes of injected AC circulating current components are $\hat{I}_{cACa} = 0.51$ A, $\hat{I}_{cACb} = 1.13$ A, and $\hat{I}_{cACc} = 1.29$ A respectively. The average ripple here is 6.5 V, and the UD is reduced to 0.5%. With the proposed method, MMC capacitor overvoltage trip is prevented when $D=0.5$.

C. Extension of the Proposed Method to Other Unbalanced Grid Conditions

TABLE II
VECTOR DEFINITION OF DIFFERENT UNBALANCED GRID CONDITIONS

Fault Types	Vector Definitions
Two-phase-to-ground fault	$\begin{cases} \hat{V}_{ga_pu} = 1 \\ \hat{V}_{gb_pu} = -\frac{1}{2}D - j\frac{\sqrt{3}}{2}D \\ \hat{V}_{gc_pu} = -\frac{1}{2}D + j\frac{\sqrt{3}}{2}D \end{cases}$
Three-phase-to-ground fault	$\begin{cases} \hat{V}_{ga_pu} = D \\ \hat{V}_{gb_pu} = -\frac{1}{2}D - j\frac{\sqrt{3}}{2}D \\ \hat{V}_{gc_pu} = -\frac{1}{2}D + j\frac{\sqrt{3}}{2}D \end{cases}$
Phase-to-phase short-circuit fault	$\begin{cases} \hat{V}_{ga_pu} = 1 \\ \hat{V}_{gb_pu} = -\frac{1}{2} - j\frac{\sqrt{3}}{2}D \\ \hat{V}_{gc_pu} = -\frac{1}{2} + j\frac{\sqrt{3}}{2}D \end{cases}$
Single-phase-to-ground fault	$\begin{cases} \hat{V}_{ga_pu} = D \\ \hat{V}_{gb_pu} = -\frac{1}{2} - j\frac{\sqrt{3}}{2} \\ \hat{V}_{gc_pu} = -\frac{1}{2} + j\frac{\sqrt{3}}{2} \end{cases}$




Fig. 7. MMC setup.

This paper thus far only discussed the two-phase-to-ground grid condition as an example. Here we elaborate how this proposed method can be easily extended to other unbalanced grid conditions:

There are 4 types of unbalanced grid conditions [19], [20]: Two-phase-to-ground fault, three-phase-to-ground fault, single-phase-to-ground fault, and phase-to-phase short circuit fault. In this paper, the vector definition of grid under two-phase-to-ground fault is expressed as equation (3). The vector definitions of other unbalanced grid conditions are shown in Table II (see below). From the vector definitions we can see that grid dip severity factor D defines the severity of the unbalanced grid, where the range of D is $[0, 1]$. Here, 1 means normal grid, while 0 means short circuit. By the type of unbalanced grid condition and changing D from $[0, 1]$, we can cover all possible fault scenarios by doing numerous parallel simulations and extracting corresponding data. This process can be significantly accelerated by paralleling the tasks using a computer cluster that contains many CPU cores. Therefore, the only limitation to extend our method to any other fault is computational capacity. If we have enough computational power, the data for other unbalanced fault conditions can be quickly collected. Then, new artificial intelligence neural network can be trained by the collected data and the circulating current reference for different unbalanced grid conditions can be calculated easily.

D. Comparison of Different MMC Operation Extension Methods

To clearly elaborate the advantages and disadvantages of the proposed machine learning method in this paper, a comparison of analytical frequency-domain based methods [4], [6]-[7], the MPC oriented method [16], and the proposed machine learning method is listed in Table III.

TABLE III
COMPARISON OF DIFFERENT MMC OPERATION EXTENSION METHODS

	Analytical Frequency-Domain Methods [4, 6, 7]	MPC Oriented Method [16]	Proposed Method
Need of Analytical Derivation?	Yes	Yes	No
Frequency Domain Model	Yes	Yes	No
Computation Burden	Low	Medium	Low
Easy to Implement to Experiment	Easy	Difficult	Easy

The Table III shows that the analytical frequency-domain based methods have a low computation burden as well as a good operation region extension performance because injecting method is proven to be effective for operation region extension. However, the main drawback of these methods is that engineers need to derive the complicated analytical equations to get the desired circulating current components. The MPC oriented method is proposed in [16] to build a model predictive control to extend the operation, in this way the parallel simulation for data collect can be eliminated. However, the non-linear controller in this method increases the difficulty for engineers not familiar with advanced control theory to implement this method in the real MMC project.

The proposed method does not need to derive any analytical equations to get the reference of circulating current. Also, the proposed method is suitable for both balanced and unbalanced grid conditions: The proposed method uses the data from parallel simulation then trains a ML model offline to get the parameters for the desired ANN model (biases, weights). In this way we can achieve a very low computation burden in real microprocessor such as DSP, dSPACE. Moreover, as this ML method is just an additional simple block for the traditional MMC controller (shown in Fig. 2), there is no need for engineers to build a non-linear MMC controller from the scratch.

IV. CONCLUSION

This paper proposed a fast method to reduce the capacitor voltage oscillations under two-phase-to-ground grid faults. This is achieved by training an artificial neural network, which explicitly maps the relationships between circulating current references and capacitor voltages. The operating region is extended by 30% with the proposed method at a minimum in all testing conditions. Therefore, the paper provides a solution to handle the non-parametric optimization of the complex internal characteristics of MMC. This method has been validated for two-phase-to-ground grid faults but can also be extended to other unbalanced grid conditions. In future work, the application of this proposed ANN method to DC circulating current components optimization will be expanded.

REFERENCES

- [1] A. Lesnicar and R. Marquardt, "An innovative modular multilevel converter topology suitable for a wide power range," in *Proc. IEEE Power Tech Conf., vol. 3, Bologna, Italy, Jun. pp. 272–277, 2003*.
- [2] M. Guan and Z. Xu, "Modeling and control of a modular multilevel converter-based HVDC system under unbalanced grid conditions," *IEEE Trans. Power Electron., vol. 27, no. 12, pp. 4858–4867, 2012*.
- [3] J. Li, G. Konstantinou, H. R. Wickramasinghe, C. D. Townsend, and J. Pou, "Capacitor Voltage Reduction in Modular Multilevel Converters under Grid Voltages Unbalances," *IEEE Trans. Power Deliv., vol. 35, no. 1, pp. 160–170, 2020*.
- [4] H. Kim, S. Kim, Y. H. Chung, D. W. Yoo, C. K. Kim, and K. Hur, "Operating Region of Modular Multilevel Converter for HVDC with Controlled Second-Order Harmonic Circulating Current: Elaborating P-Q Capability," *IEEE Trans. Power Deliv., vol. 31, no. 2, pp. 493–502, 2016*.
- [5] D. Ronanki and S. S. Williamson, "Failure Prediction of Submodule Capacitors in Modular Multilevel Converter by Monitoring the Intrinsic Capacitor Voltage Fluctuations," *IEEE Trans. Ind. Electron., vol. 67, no. 4, pp. 2585–2594, 2020*.
- [6] S. Norrga, L. Ångquist and K. Ilves, "Operating region extension for multilevel converters in HVDC applications by optimisation methods," *10th IET International Conference on AC and DC Power Transmission (ACDC 2012), Birmingham, pp. 1–6, 2012*.
- [7] J. Pou, S. Ceballos, G. Konstantinou, V. G. Agelidis, R. Picas, and J. Zaragoza, "Circulating current injection methods based on instantaneous information for the modular multilevel converter," *IEEE Trans. Ind. Electron., vol. 62, no. 2, pp. 777–788, 2015*.
- [8] J. Li, G. Konstantinou, H. R. Wickramasinghe, J. Pou, X. Wu, and X. Jin, "Investigation of MMC-HVDC operating region by circulating current control under grid imbalances," *Electr. Power Syst. Res., vol. 152, pp. 211–222, 2017*.
- [9] K. Ilves, A. Antonopoulos, L. Harnefors, S. Norrga, L. Ångquist, and H. P. Nee, "Capacitor voltage ripple shaping in modular multilevel converters allowing for operating region extension," in *Proc. Industrial Electron, pp. 4403–4408, 2011*.
- [10] B. Li, Y. Zhang, G. Wang, W. Sun, D. Xu, and W. Wang, "A Modified Modular Multilevel Converter with Reduced Capacitor Voltage Fluctuation," *IEEE Trans. Ind. Electron., vol. 62, no. 10, pp. 6108–6119, 2015*.
- [11] K. Sharifabadi, L. Harnefors, H.-P. Nee, S. Norrga, and R. Teodorescu, *Design, Control and Application of Modular Multilevel Converters for HVDC Transmission Systems*. 2016. New York, NY, USA: Wiley, 2016.
- [12] J. Moon, S. Member, J. Park, and D. Kang, "A Control Method of HVDC-Modular Multilevel Converter Based on Arm Current Under the Unbalanced Voltage Condition," *IEEE Trans. Power Deliv., vol. 30, no. 2, pp. 1–8, 2014*.
- [13] X. Shi, Z. Wang, B. Liu, Y. Li, L. M. Tolbert, and F. Wang, "Steady-State Modeling of Modular Multilevel Converter under Unbalanced Grid Conditions," *IEEE Trans. Power Electron., vol. 32, no. 9, pp. 7306–7324, 2017*.
- [14] J. W. Moon, C. S. Kim, J. W. Park, D. W. Kang, and J. M. Kim, "Circulating current control in MMC under the unbalanced voltage," *IEEE Trans. Power Deliv., vol. 28, no. 3, pp. 1952–1959, 2013*.
- [15] M. Vasiladiotis, N. Cherix, and A. Rufer, "Impact of Grid Asymmetries on the Operation and Capacitive Energy Storage Design of Modular Multilevel Converters," *IEEE Trans. Ind. Electron., vol. 62, no. 11, pp. 6697–6707, 2015*.
- [16] J. M. Rodriguez-Bernuz and A. Junyent-Ferre, "Operating Region Extension of a Modular Multilevel Converter using Model Predictive Control: a Single Phase Analysis," *IEEE Trans. Power Deliv. Early Access*.
- [17] T. Dragicevic and M. Novak, "Weighting Factor Design in Model Predictive Control of Power Electronic Converters: An Artificial Neural Network Approach," *IEEE Trans. Ind. Electron., vol. 66, no. 11, pp. 8870–8880, 2019*.
- [18] T. Dragicevic, P. Wheeler, and F. Blaabjerg, "Artificial Intelligence Aided Automated Design for Reliability of Power Electronic Systems," *IEEE Trans. Power Electron., vol. 34, no. 8, pp. 7161–7171, 2019*.
- [19] K. Hornik, M. Stinchcombe, and H. White, "Multilayer feedforward networks are universal approximators" *Neural Networks vol. 2, pp.*

IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS

- 359–366, 1989.
- [20] M. H. Bollen, Understanding Power Quality Problems. New York, NY, USA: Wiley, 2000.
- [21] T. Tanaka, K. Ma, and S. Member, “Asymmetrical Reactive Power Capability of Modular Multilevel Cascade Converter (MMCC) based STATCOMs for Offshore Wind Farm,” *IEEE Trans. Power Electron.*, vol. 34, no. 6, pp. 5147-5164, 2019.
- [22] A. Antonopoulos, L. Ångquist, L. Harnefors, K. Ilves, and H. P. Nee, “Global asymptotic stability of modular multilevel converters,” *IEEE Trans. Ind. Electron.*, vol. 61, no. 2, pp. 603–612, 2014.